

## HEADWALL & SAFETY GUARD FOR PIPE RISERS

ESTIMATED QUANTITIES					
MARK	ND.	SIZE	LENGTH		
A	4	4" × 4"	6'- 0"		
В	3	2' × 12'	4'- 8"		
С	1	2' × 6'	4'- 8"		
D	3	2' × 6'	4'- 4"		
Board Feet - 77					

NDTES:

- All wood shall be pressure-treated with a creosote-coaltar solution or a pentachlorophenol solution.
- All joints shall be nailed with spikes using at least 2 in each joint.
- 3. Posts shall be 4' square, notched as shown, with bottom left square if not driven.
- 4. The steel mat covering shall be 6x12 style two-way welded galvanized wire fabric or welded galvanized cattle panels with 1/4" rods and 4"x 8" openings. All splices shall be made at the corners. The edge of the mat shall be made at corners. The edge of the mat shall be bent at least 2" around the corners and the mat fasten to the frame by 2" long galvanized staples on 6" centers.

REFERENCE	A LIDCC	STANDARD DVG. ND.
Project		IL-576
Designed Date		SHEET 2 DF 2
Approved Date	Natural Resources Conservation Service	DATE 2-18-94